

Certified Mail
Return Receipt Requested

001933

July 9, 2012

RECEIVED
JUL 12 2012
3AP20

USEPA Region III
Air Protection Division
1650 Arch Street
Philadelphia, PA 19103-2029

Re: Notification of Date Construction Commenced for Proposed SI Engines
40 CFR 60, Subpart JJJJ and 40 CFR 63, Subpart ZZZZ
Transcontinental Gas Pipe Line Company, LLC
Compressor Station 170 - Appomattox, Appomattox County, VA
Air Permit Number: SCRO30863

Dear Director:

Transcontinental Gas Pipe Line Company, LLC (Transco) will be submitting an application to the Virginia Department of Environmental Quality to obtain approval for the construction of (2) new electric generators at Compressor Station 170 located in Appomattox, Appomattox County, VA. The additional generators will be (2) Waukesha Pearce VGF48GSID 4 stroke rich burn natural gas fired auxiliary generators will be constructed. As the owner of the proposed engine, Transco is required to comply with the notification provisions of 40 Code of Federal Regulations (40 CFR), §60.4245(c) and §60.7(a)(1) because the proposed engine is subject to Spark Ignition Reciprocating Internal Combustion (IC) Engine New Source Performance Standard (40 CFR Part 60, Subpart JJJJ) and (40 CFR 63, Subpart ZZZZ).

According to §60.4230(a), the date an engine is ordered is considered the date construction commenced. A notification of construction is due to be submitted 30 days from this date. Transco finalized the purchase order for the compressor engine on July 2, 2012.


Additional information for this engine is hereby provided:

Name of Engine Owner or Operator:	<u>Transcontinental Gas Pipe Line Company, LLC (Transco)</u>
Address of Engine Owner or Operator:	<u>2800 Post Oak Boulevard, Houston, Texas 77056</u>
Name and Physical Address of Facility:	<u>Transco Compressor Station 170</u> <u>2444 Pumping Station Road</u> <u>Appomattox, VA 24522</u>
Engine Rating:	<u>1,065 HP</u>
Engine Serial Number:	<u>Not Available</u>
Engine Make/Model:	<u>Waukesha Pearce VGF48GSID</u>
Fuel:	<u>Natural Gas</u>
Engine Type:	<u>4 Cycle Rich-Burn</u>
Emission Control Information:	<u>Non-Selective Catalytic Reduction</u>

Name of Engine Owner or Operator:	<u>Transcontinental Gas Pipe Line Company, LLC (Transco)</u>
Address of Engine Owner or Operator:	<u>2800 Post Oak Boulevard, Houston, Texas 77056</u>
Name and Physical Address of Facility:	<u>Transco Compressor Station 170</u> <u>2444 Pumping Station Road</u> <u>Appomattox, VA 24522</u>
Engine Rating:	<u>1,065 HP</u>
Engine Serial Number:	<u>Not Available</u>
Engine Make/Model:	<u>Waukesha Pearce VGF48GSID</u>
Fuel:	<u>Natural Gas</u>
Engine Type:	<u>4 Cycle Rich-Burn</u>
Emission Control Information:	<u>Non- Selective Catalytic Reduction</u>

Should you have any questions regarding this submittal, please do not hesitate to contact me at (713) 215-2873 or chris.adams@williams.com.

Sincerely,



Chris Adams
Environmental Scientist III
Environmental Compliance – Air Quality